

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No - 1193

DATE- 05/03/25

It is certified that an inspection team headed by JEN. Rajesh Thapa from P.H.E.D Jhotwara Jaipur inspected the St Teresa's School, Niwaru Road, Jaipur on 05.03.2025 and found that St Teresa's School, Niwaru Road, Jaipur has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the **NATIONAL SCHOOL SANITION MANUAL OF Central Govt.**

The above certificate is valid for a period of 12 months.

Encl. Superintending Chemist PHED Lab

Sample Test report Bact. Letter No. 4480 Date 25.02.2025

Sample Test report Chem. Letter No. 4478 Date 25.02.2025

Signature with seal.....

Name: Yogesh Kumar Jangir

Designation: Assistant Engineer
PHED City Health and Sanitation Division (North)
Jhotwara नगर उपखण्ड-III (उत्तर)
Jaipur झोटवाड़ा जयपुर।


नगरीष्ठ अभियन्ता
नगर उपखण्ड तृतीय (उत्तर)
जन स्वास्थ्य अभि० विभाग
झोटवाड़ा (जयपुर)

Copy to:

Principal,
St Teresa School
Niwaru Road, Jhotwara, Jaipur
302012


Principal
St. Teresa's School
Niwaru Road, Jhotwara
Jaipur (Raj.)


Manager
St. Teresa's School
Niwaru Road, Jhotwara, Jaipur

OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2024-2025/ 4478

Date: 25/02/2025

To,
Principal
St. Teresa's School Niwaru
Road, Jhotawara,
Jaipur
Date of Receipt: 19.02.25

The sample was not collected
by this laboratory.

Not Valid for water
quality / Legal Cases


Particulars			RO Water
value as per I.S.:10500/2012			
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			19.02.2025
Lab. Sample No.			P-170
1. pH	6.5-8.5	6.5-8.5	6.86
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo ₃) mg/l	200	600	40
6. Total Hardness (as CaCo ₃) mg/l	200	600	30
7. Calcium (as Ca) mg/l	75	200	8
8. Magnesium (as Mg) mg/l	30	100	2
9. Chloride (as Cl-) mg/l	250	1000	10
10. Nitrates (as NO ₃ -) mg/l	45	45	1
11. Sulphate(as So ₄ - 2)mg/l	200	400	1
12. Total Dissolved Solids mg/l	500	2000	70
13. Fluoride mg/l	1.00	1.5	0.10
14. Iron mg/l	1.0	No Relaxation	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send by you


Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2024-2025/
Copy to:- 1. The Chief Chemist, PHED Raj. Jaipur

Date:


Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur


Principal
St. Teresa's School
Niwaru Road, Jhotwara
Jaipur (Raj.)


Manager
St. Teresa's School
Niwaru Road, Jhotwara, Jaipur

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2024-25/ 4480

Dated: 11/25/2/25

To
St. Teresa's School
Niwaru Road, Jhotwara
Jaipur

Reference : - Your Application on dated 19/02/2025
GRN NO. : -101026679 Paid on Date 19/02/2025

Distt: Jaipur
Tehsil: Jaipur

Sample No.	Date of Collection	Date of Examination	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:110 3456	19/02/2025	19/02/2025	Jaipur	RO St. Teresa's School	Nil	Nil	Satisfactory

Remark-1-Not Valid for water quality Legal cases
2- The Sample was not collected by this laboratory

Gent
Superintending Chemist(HM & Jaipur City)
PHED, Laboratory, Jaipur

No: Lab/Bact/2024-25/
Copy to:
1. The Chief Chemist, PHED, Rajasthan, Jaipur

Dated:

~~Superintending Chemist (HM & Jaipur City)
PHED, Laboratory, Jaipur~~

Principal
Principal
St. Teresa's School
Niwaru Road, Jhotwara
Jaipur (Raj.)

Manager
Manager
St. Teresa's School
Niwaru Road, Jhotwara, Jaipur